

# BACnet CONFORMANCE CERTIFICATE



**No. BTL-31325**

WSPCert attests the conformance of the following BACnet implementation to the BACnet standard ISO 16484-5 protocol revision 1.19. The attested conformance refers to the BACnet Interoperability Building Blocks (BIBBs) listed on the BTL Listing bearing the above-mentioned BTL-number.

The BACnet implementation has fulfilled the requirements according to the test standard ISO 16484-6, the BTL Test Plan 23.3 and the BTL Testing Policies, see Test Report number TC51418 of Protocol Test Lab.

|                                       |
|---------------------------------------|
| Product name (B-BC,B-RTR,B-BBMD,B-GW) |
| <b>OptiFlex™ Integration Router</b>   |
| <b>Model(s) OFINT-E2</b>              |
| Firmware version                      |
| <b>108.06.20169</b>                   |
| Vendor                                |
| <b>Automated Logic Corporation</b>    |
| <b>1150 Roberts Blvd.</b>             |
| <b>Kennesaw, GA 30144, USA</b>        |

This certificate is valid until **31-Mar-2030**.

**31-Mar-2025**

Date of Initial Certification

A handwritten signature in blue ink, appearing to read 'G. Weinmann', is positioned above the name of the Head of Certification Body.

Dipl.-Ing. G. Weinmann  
Head of Certification Body